

Watchguard Generator Service

Level

13



Level 13: Caterpillar UPS Inspection – Annually.

- Clean and inspect flywheel as per Caterpillar specifications
 - Replace air filters
 - Check oil level
 - Clean sight gauge
 - Check fault and warning logs
 - Change oil in vacuum pump
 - Hook up computer, complete full system check, create UPS discharge
- Recommended every 12 months



Watchguard Service is a Ziegler preventive maintenance and inspection program, custom designed to help reduce generator operating costs, prolong component life and increase the overall reliability of your equipment.

ZIEGLER 
Power Systems

8050 COUNTY RD. 101 E.
SHAKOPEE, MN 55379
952.445.4292
888.320.4292

1500 ZIEGLER DR. N.W.
ALTOONA, IA 50009
515.957.3800
800.342.7002